

Facility	Location	Test Location	Test ID #	Test Result	Exceeds 15ppm	Action Taken
City Parks and Market Square	Deerpath Park - 400 Hastings Road (behind Deerpath School)	On path near the batting cage	TEST ID #: CLF 93	< 2.0		
	Deerpath Park - 400 Hastings Road (behind Deerpath School)	Behind Ball diamond #1	TEST ID #: CLF 94	< 2.0		
	Deerpath Park - 400 Hastings Road (behind Deerpath School)	Behind Ball diamond #2	TEST ID #: CLF 95	< 2.0		
	Deerpath Park - 400 Hastings Road (behind Deerpath School)	Behind Ball diamond #3	TEST ID #: CLF 96	< 2.0		
	Deerpath Park - 400 Hastings Road (behind Deerpath School)	Behind Ball diamond #4	TEST ID #: CLF 97	< 2.0		
	Everett Park - 1190 Everett School Road	North classroom sink	TEST ID #: CLF 68	< 2.0		
	Everett Park - 1190 Everett School Road	South classroom sink	TEST ID #: CLF 69	< 2.0		
	Everett Park - 1190 Everett School Road	Drinking fountain exterior West side	TEST ID #: CLF 70	< 2.0		
	Everett Park - 1190 Everett School Road	South of Baseball field a walk path	TEST ID #: CLF 86	< 2.0		
	Northcroft Ridge - 1365 S. Ridge Road	Between playground and tennis courts	TEST ID #: CLF 87	< 2.0		
	South Park - 150 S. Maywood Road	Drinking fountain exterior North side	TEST ID #: CLF 71	< 2.0		
	South Park - 150 S. Maywood Road	South of tennis courts	TEST ID #: CLF 88	< 2.0		
	South Park - 150 S. Maywood Road	Behind Baseball diamond #1	TEST ID #: CLF 89	< 2.0		
	South Park - 150 S. Maywood Road	Behind baseball diamond #2	TEST ID #: CLF 109	< 2.0		
	Triangle Park - Corners of Walnut, Washington & Deerpath	In boulder located in the South East corner	TEST ID #: CLF 92	6.4		
	Waveland Park - 600 S. Waveland Road	Drinking fountain exterior South side	TEST ID #: CLF 72	< 2.0		
	Waveland Park - 600 S. Waveland Road	Between Baseball fields on Butler side	TEST ID #: CLF 90	< 2.0		
	Waveland Park - 600 S. Waveland Road	On path near tennis courts	TEST ID #: CLF 91	< 2.0		
	West Park - 850 N. Summit Avenue	Drinking fountain under pavilion	TEST ID #: CLF 73	< 2.0		
	Market Square - 724 N Western Ave	Northside of square	TEST ID #: CLF 84	3.3		
Market Square - 724 N Western Ave	Southside of square	TEST ID #: CLF 85	3.5			
Forest Park and Lakefront Facilities	Boat Ramp - 601 N. Lake Road	Drinking fountain exterior East side	TEST ID #: CLF 63	< 2.0		
	Forest Park - 801 North Lake Road	In the South Parking lot	TEST ID #: CLF 104	< 2.0		
	Forest Park - 801 North Lake Road	At the top of the North Staircase	TEST ID #: CLF 105	< 2.0		
	Lakefront Facilities - 501-701 Lake Road	On path across from South Pavilion	TEST ID #: CLF 98	< 2.0		
	Lakefront Facilities - 501-701 Lake Road	On path outside Boat Ramp Pavilion	TEST ID #: CLF 99	< 2.0		
	Lakefront Facilities - 501-701 Lake Road	On wooden walkway	TEST ID #: CLF 100	4.2		
	Lakefront Facilities - 501-701 Lake Road	On path at the playground	TEST ID #: CLF 101	< 2.0		
	Lakefront Facilities - 501-701 Lake Road	South of North Pavilion on sidewalk	TEST ID #: CLF 102	< 2.0		
	Lakefront Facilities - 501-701 Lake Road	At the bottom of the North Staircase	TEST ID #: CLF 103	< 2.0		
	North Beach House - 701 N. Lake Road	Sink in lifeguard station	TEST ID #: CLF 64	< 2.0		
	North Beach House - 701 N. Lake Road	Sink in snack shop	TEST ID #: CLF 65	< 2.0		
	North Beach House - 701 N. Lake Road	Drinking fountain exterior South side	TEST ID #: CLF 66	< 2.0		
	South Beach House - 501 N. Lake Road	Drinking fountain exterior East side	TEST ID #: CLF 67	< 2.0		
Golf Course	Golf Course Club House - 500 W. Deerpath Rd	Drinking fountain near restrooms	TEST ID #: CLF 75	< 2.0		
	Golf Course Club House - 500 W. Deerpath Rd	Hand sink in kitchen	TEST ID #: CLF 76	< 2.0		
	Golf Course Club House - 500 W. Deerpath Rd	Kitchenette sink in pro shop back room	TEST ID #: CLF 77	< 2.0		
	Golf Course Garage - 500 W. Deerpath Rd	Kitchen sink in break room	TEST ID #: CLF 74	< 2.0		
ELAWA Farm	ELAWA Cottage -1401 Middlefork Drive	Kitchen Sink	TEST ID #: CLF 16	< 2.0		
	ELAWA Farms - 1401 Middlefork Drive	Visitor's Center Kitchen Sink	TEST ID #: CLF 9	< 2.0		
	ELAWA Farms - 1401 Middlefork Drive	Drinking Fountain near restrooms	TEST ID #: CLF 10	< 2.0		
	ELAWA Farms - 1401 Middlefork Drive	Kitchen Sink	TEST ID #: CLF 11	< 2.0		
	ELAWA Farms - 1401 Middlefork Drive	East Classroom sink	TEST ID #: CLF 12	< 2.0		
	ELAWA Farms - 1401 Middlefork Drive	West classroom sink	TEST ID #: CLF 13	< 2.0		
	ELAWA Farms - 1401 Middlefork Drive	Open Market sink	TEST ID #: CLF 14	< 2.0		
	ELAWA Farms - 1401 Middlefork Drive	West Building South Meeting room sink	TEST ID #: CLF 15	< 2.0		
	ELAWA Park -1401 Middlefork Drive	On path at the basketball court	TEST ID #: CLF 107	3.5		
Recreation Center and CROYA	Recreation Center - 400 Hastings Road	Main office kitchen sink	TEST ID #: CLF 38	< 2.0		
	Recreation Center - 400 Hastings Road	Bottle filling station in fitness center	TEST ID #: CLF 39	< 2.0		
	Recreation Center - 400 Hastings Road	Bottle filling station in main hallway by vending	TEST ID #: CLF 40	< 2.0		
	Recreation Center - 400 Hastings Road	Drinking fountain Gym North East corner	TEST ID #: CLF 41	< 2.0		
	Recreation Center - 400 Hastings Road	Drinking fountain gym South West corner	TEST ID #: CLF 42	2.2		
	Recreation Center - 400 Hastings Road	Drinking fountain North hallway East end	TEST ID #: CLF 43	< 2.0		
	Recreation Center - 400 Hastings Road	Drinking fountain by SW main entrance	TEST ID #: CLF 44	< 2.0		
	Recreation Center - 400 Hastings Road	Kinderhaven kitchen sink	TEST ID #: CLF 45	< 2.0		
	Recreation Center - 400 Hastings Road	Kinderhaven kids kitchen sink	TEST ID #: CLF 46	< 2.0		
	Recreation Center - 400 Hastings Road	In East playground area	TEST ID #: CLF 106	5.1		
	CROYA - 400 Hastings Road	Basement Kitchen Sink	TEST ID #: CLF 6	< 2.0		
	CROYA - 400 Hastings Road	1st Floor Kitchen sink	TEST ID #: CLF 7	< 2.0		
	CROYA - 400 Hastings Road	1st Floor Bottle Filling Station	TEST ID #: CLF 8	< 2.0		
	Grove Cultural Campus	Sterling Hall - 60 E. Old Mill Road	1st floor drinking fountain	TEST ID #: CLF 49	< 2.0	
Sterling Hall - 60 E. Old Mill Road		1st floor kitchen sink	TEST ID #: CLF 50	< 2.0		
Volwiler Hall - 40 E. Old Mill Road		1st floor kitchen	TEST ID #: CLF 55	419	✓	Fixture taken out of service on October 7, 2016
Volwiler Hall - 40 E. Old Mill Road		1st floor drinking fountain, main hallway	TEST ID #: CLF 56	5.7		
Volwiler Hall - 40 E. Old Mill Road		Basement kitchen sink in CRC	TEST ID #: CLF 57	2.3		
Volwiler Hall - 40 E. Old Mill Road		Basement drinking fountain in CRC	TEST ID #: CLF 58	3.7		
Bennett Hall - 50 E. Old Mill Road		1st floor kitchen sink	TEST ID #: CLF 59	5.4		
Bennett Hall - 50 E. Old Mill Road		2nd floor kitchen sink	TEST ID #: CLF 60	11.8		
Senior Center - 100 E. Old Mill Road		1st floor Drinking fountain	TEST ID #: CLF 47	< 2.0		
Senior Center - 100 E. Old Mill Road		1st floor kitchen sink	TEST ID #: CLF 48	< 2.0		
Gorton Community Center and Lake Forest / Lake Bluff Historical Center	Gorton - 400 E. Illinois Road	1st floor kitchen sink	TEST ID #: CLF 17	< 2.0		
	Gorton - 400 E. Illinois Road	1st floor main hallway drinking fountain	TEST ID #: CLF 18	< 2.0		
	Gorton - 400 E. Illinois Road	Basement kitchen sink	TEST ID #: CLF 19	< 2.0		
	Gorton - 400 E. Illinois Road	Basement East end drinking fountain	TEST ID #: CLF 20	< 2.0		
	Gorton - 400 E. Illinois Road	Basement near kitchen drinking fountain	TEST ID #: CLF 21	< 2.0		
	Gorton - 400 E. Illinois Road	2nd floor kitchen sink	TEST ID #: CLF 22	< 2.0		
	Gorton - 400 E. Illinois Road	2nd floor drinkinf fountain main hall East	TEST ID #: CLF 23	< 2.0		
	Gorton - 400 E. Illinois Road	2nd floor drinking fountain main hall West	TEST ID #: CLF 24	2.3		
	Gorton - 400 E. Illinois Road	2nd floor drinking fountain between restrooms	TEST ID #: CLF 25	< 2.0		
	Gorton - 400 E. Illinois Road	DIC West classroom sink	TEST ID #: CLF 26	< 2.0		
	Gorton - 400 E. Illinois Road	DIC Center classroom sink	TEST ID #: CLF 27	< 2.0		
	Gorton - 400 E. Illinois Road	DIC East classroom sink	TEST ID #: CLF 28	< 2.0		
	LF/LB Hist Center - 361 E. Westminster	1st floor kitchen sink	TEST ID #: CLF 61	13.6		
	LF/LB Hist Center - 361 E. Westminster	1st floor drinking fountain	TEST ID #: CLF 62	17.6	✓	Fixture taken out of service on October 7, 2016
Train Stations	CNW (East) - 701 N. McKinley Road	Drinking Fountain	TEST ID #: CLF 4	< 2.0		
	CNW (West) - 695 N. Western Avenue	Kitchenette sink	TEST ID #: CLF 5	3.4		
	TTD - 911 S. Telegraph Road	Coffee shop small sink	TEST ID #: CLF 51	< 2.0		
	TTD - 911 S. Telegraph Road	Main lobby drinking fountain	TEST ID #: CLF 52	< 2.0		
City Hall, Public Safety Building, and Water Plant	City Hall - 220 E. Deerpath Road	1st Floor Kitchen sink	TEST ID #: CLF 1	< 2.0		
	City Hall - 220 E. Deerpath Road	2nd Floor Drinking fountain	TEST ID #: CLF 2	< 2.0		
	City Hall - 220 E. Deerpath Road	2nd Floor Kitchenette sink	TEST ID #: CLF 3	< 2.0		
	City Hall - 220 E. Deerpath Road	In boulder located in the South West garden	TEST ID #: CLF 108	< 2.0		
	Public Safety - 255 W. Deerpath Road	Sink in old dispatch	TEST ID #: CLF 29	< 2.0		
	Public Safety - 255 W. Deerpath Road	Sink in reports room near jail	TEST ID #: CLF 30	< 2.0		
	Public Safety - 255 W. Deerpath Road	Sink in I & Y	TEST ID #: CLF 31	< 2.0		
	Public Safety - 255 W. Deerpath Road	Kitchen sink in lower level break room	TEST ID #: CLF 32	3.7		
	Public Safety - 255 W. Deerpath Road	Kitchen sink in Fire Dept	TEST ID #: CLF 33	< 2.0		
	Public Safety - 255 W. Deerpath Road	Drinking fountain basement in break room	TEST ID #: CLF 34	< 2.0		
	Public Safety - 255 W. Deerpath Road	Drinking fountain basement in fitness room	TEST ID #: CLF 35	< 2.0		
	Public Safety - 255 W. Deerpath Road	Drinking fountain basement hallway near restrooms	TEST ID #: CLF 36	2.3		
	Public Safety - 255 W. Deerpath Road	1st floor drinking fountain behind classroom	TEST ID #: CLF 37	< 2.0		
	Water Plant - 1441 N. Lake Road	Kitchen sink	TEST ID #: CLF 53	< 2.0		
Water Plant - 1441 N. Lake Road	Drinking fountain	TEST ID #: CLF 54	< 2.0			